

# Evaluation of a Cryogenic Air Supply as a Breathable Air Supply for Refuge Alternatives




**Lincan Yan, Ph.D.**

**Pittsburgh Mining Research Division  
RA Partnership**

**November 17-18, 2021**




# Objective




- To simulate human breathing in refuge alternatives
- To characterize the cryogenic air supply as a breathable air source


The main components of a cryogenic air supply are the *dewar* and the *cryocooler*.




A *dewar* is a double-walled, vacuum-insulated container used to store liquefied gases at cryogenic temperatures ( $< -90^{\circ}\text{C}$ ,  $< -130^{\circ}\text{F}$ ).



A *cryocooler* is an electrically powered refrigeration system designed to maintain liquids at cryogenic temperatures.




The cryocooler is controlled by a *pressure switch* with adjustable low pressure (off) and high pressure (on) setpoints.






In case the cryocooler loses power or malfunctions, a *pressure relief valve* limits the pressure inside the dewar.




To deliver air from the cryogenic air supply, the cryocooler is turned off and a *vacuum-jacketed hose* is connected to a *heat exchanger* in the space where air is needed.






Then, the *pressure buildup* valve is opened. The *vapor pressure* in the dewar and the *pressure build-up circuit* force liquid air to flow from the dewar to the heat exchanger.



As the *liquid air* flows through the heat exchanger, it absorbs heat from the surroundings converting the liquid to *gaseous air*.



# Air and propane delivery, mass flow controllers for the HBS



Air delivery pump



Air mass controller




Propane gas line

Propane gas controller


Safety solenoid valve

# Sensor locations



- T/RH sensor
- O<sub>2</sub> sensor
- CO<sub>2</sub> sensor

# Concept of Human Breathing Simulator (HBS)



Gas	weight, gram	Normalized
$C_3H_8$	44.1	1
$O_2$	160	3.63
Air	686.69	15.57
$CO_2$	132.1	2.99
$H_2O$	72.1	1.63

# Test #1 (96 hours)—O<sub>2</sub> consumption rate from federal regulations

- Based on oxygen consumption rate from federal regulations  
1.32 cu ft or 37.4 liters of pure oxygen per hour/person
- Cryo air supply
- CO<sub>2</sub> scrubbing curtains



## Test #2 (96 hours)—University of South Florida consumption rate

- Based on oxygen consumption rate of University of South Florida  
~19 liters pure oxygen per hour/person
- Cryo air supply
- CO<sub>2</sub> scrubbing curtains



	Federal Regulation:			
	O <sub>2</sub> consumption at 1.32 ft <sup>3</sup> /hr/person		CO <sub>2</sub> generation at 1.08 ft <sup>3</sup> /hr/person	
	21 Miners	Propane Burner		
Fuel burning rate	NA	0.28 kg/hr (0.62 LB/hr)		
O <sub>2</sub> mass consumption rate	1.01 kg/hr (2.23 LB/hr)			
O <sub>2</sub> volume consumption rate	0.78 m <sup>3</sup> /hr (27.7 ft <sup>3</sup> /hr)			
CO <sub>2</sub> mass generation rate	1.1 kg/hr (2.4 LB/hr)	0.8 kg/hr (1.76 LB/hr)		
CO <sub>2</sub> volume generation rate	0.64 m <sup>3</sup> /hr (22.7 ft <sup>3</sup> /hr)	0.47 m <sup>3</sup> /hr (16.6 ft <sup>3</sup> /hr)		

*“This information is distributed solely for the purpose of pre dissemination peer review under applicable information quality guidelines. It has not been formally disseminated by the National Institute for Occupational Safety and Health, Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”*


	Federal Regulation:		Bernard Research:	
	O <sub>2</sub> consumption at 1.32 ft <sup>3</sup> /hr/person CO <sub>2</sub> generation at 1.08 ft <sup>3</sup> /hr/person		O <sub>2</sub> consumption at 0.67 ft <sup>3</sup> /hr/person CO <sub>2</sub> generation at 0.60 ft <sup>3</sup> /hr/person	
	21 Miners	Propane Burner	21 Miners	Propane Burner
Fuel burning rate	NA	0.28 kg/hr (0.62 LB/hr)	NA	0.14 kg/hr (0.31 LB/hr)
O <sub>2</sub> mass consumption rate	1.01 kg/hr (2.23 LB/hr)		0.52 kg/hr (1.15 LB/hr)	
O <sub>2</sub> volume consumption rate	0.78 m <sup>3</sup> /hr (27.7 ft <sup>3</sup> /hr)		0.4 m <sup>3</sup> /hr (14.1 ft <sup>3</sup> /hr)	
CO <sub>2</sub> mass generation rate	1.1 kg/hr (2.4 LB/hr)	0.8 kg/hr (1.76 LB/hr)	0.63 kg/hr (1.39 LB/hr)	0.42 kg/hr (0.93 LB/hr)
CO <sub>2</sub> volume generation rate	0.64 m <sup>3</sup> /hr (22.7 ft <sup>3</sup> /hr)	0.47 m <sup>3</sup> /hr (16.6 ft <sup>3</sup> /hr)	0.36 m <sup>3</sup> /hr (12.6 ft <sup>3</sup> /hr)	0.24 m <sup>3</sup> /hr (8.47 ft <sup>3</sup> /hr)

*“This information is distributed solely for the purpose of pre dissemination peer review under applicable information quality guidelines. It has not been formally disseminated by the National Institute for Occupational Safety and Health, Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”*



# Test #1 results—O<sub>2</sub> level ~22%, CO<sub>2</sub> level <1%



# Test #1 results—cryo air weight loss at 25.5 lb/hr




# Test #2 results—O<sub>2</sub> level 20%-22%, CO<sub>2</sub> level <1%





# Test #2 results—cryo air weight loss at 25.1 lb/hr





# Test #3 (2 hours)—how fast the %CO<sub>2</sub> will increase w/o mitigation

- NO CO<sub>2</sub> scrubbing curtains
- Based on federal regulation oxygen consumption rate
- Cryo air supply



# Test #3 result—CO<sub>2</sub> will exceed the 1% limit within 1 hour



*"This information is distributed solely for the purpose of pre dissemination peer review under applicable information quality guidelines. It has not been formally disseminated by the National Institute for Occupational Safety and Health, Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."*

# Conclusion

- Both 96-hour tests show the cryogenic air supply can maintain the O<sub>2</sub> and CO<sub>2</sub> level within the federal regulation limit
- CO<sub>2</sub> level will increase dramatically without CO<sub>2</sub> mitigation
- The 2000-liter CryoRASS has the capacity to provide breathable air for 21 people for at least 96 hours
- Need the capacity of adjusting the cryo air flow rate from inside

# Thank you!

Lincan Yan  
[LYan1@cdc.gov](mailto:LYan1@cdc.gov)  
412-386-6876



**NIOSH Mining Program**  
[www.cdc.gov/niosh/mining](http://www.cdc.gov/niosh/mining)

