

Evaluation of the 12.5 cfm/Miner Requirement for Refuge Alternatives Supplied with Fresh Air



Cory DeGennaro

Mechanical Engineer

Pittsburgh Mining Research Division

RA Partnership

November 17-18, 2021

Regulations state that O_2 must be maintained between 18.5%–23% and CO_2 must be maintained below 1%

- RAs can use O_2 cylinders and CO_2 scrubbing material
- RAs using O_2 cylinders must supply O_2 at **1.32 cfh per person**
- RAs using O_2 cylinders must remove CO_2 at **1.08 cfh per person**
- RAs using a BAS must supply fresh air at **12.5 cfm per person**
- RAs using a BAS do not need scrubbing material due to high volume of fresh air



Test equipment was repurposed to evaluate the amount of fresh air flow required to maintain O₂ and CO₂ levels

- CASE Lab: sealed shipping container
 - Volume for 21 occupants based on regulations
 - No CO₂ scrubbing material was used
- O₂ and CO₂ monitors
- Safety-related sensors
- Human Breathing Simulator
- Gas mass flow controllers



Propane combustion and supplemental CO₂ were used to match human O₂ consumption and CO₂ generation

- The propane combustion equation ($C_3H_8 + 5O_2 \rightarrow 3CO_2 + 4H_2O$) was used to calculate mass flow rates for each gas on a per-person basis using mandated rates for O₂ consumption and CO₂ generation

Type of gas	Approximate mass flow rate per person (grams/minute)
O ₂ to be consumed	0.80
C ₃ H ₈ needed to consume O ₂	0.22
Combustion air (including 20% excess)	4.45
CO ₂ from combustion	0.66
CO ₂ from human breathing	0.90
Supplemental CO ₂ needed (Human breathing - Combustion)	0.24



A centrifugal fan simulated a BAS by providing fresh air into the enclosure to mitigate CO₂ rise


- Consists of a centrifugal fan, variable frequency drive, and air flow measurement station
- Air flow is measurable from 100–1,100 cfm
- The FAF rate was adjusted based on interior conditions




Iterative fresh air flow rate reductions allowed us to identify a relationship between fresh air and CO₂ levels

- Begin simulating human breathing (propane combustion and supplemental CO₂ flow)
- Begin with a fresh air flow rate of 12.5 cfm per person
- Allow interior CO₂ to stabilize
- Adjust fresh air flow rate
 - Reduce by 50% if CO₂ is less than 1%
 - Increase by 50% if CO₂ is greater than 1%
- Continue until 1% is reached
- *O₂ and CO₂ concentrations were averaged over the interior volume**
- *Testing began with 21 simulated occupants (262.5 cfm total)**
- *Minimum measurable fresh air flow limitations required increased number of simulated occupants**
- *Occupancies tested ranged from 21–58**


CO₂ concentration reached 0.2% for 12.5 cfm/person (626.5 cfm total) and 0.37% for 6.25 cfm/person (131 cfm total) for 21 simulated occupants




CO₂ concentration reached ~0.54% for 3 cfm/person (102 cfm total) for 34 simulated occupants




CO₂ concentration reached 0.79% for 2.55 cfm/person (102 cfm total) for 40 simulated occupants




O₂ levels remained within the mandated range for 2.55 cfm/person



CO₂ concentration reached 1.1% for 1.76 cfm/person (102 cfm total) and 0.93% for 2.12 cfm/person (123 cfm total) for 58 simulated occupants





O₂ levels remained within the mandated range for lowest tested fresh air flow rate of 1.76 cfm/person





A theoretical model was developed to predict %CO₂ and validated using test data

- Input parameters:



The model predicts that a fresh air flow rate of 1.87 cfm per person corresponds to 1% CO₂



N	Federal regulation of CFR FAF at 12.5 cfm/person (cfm)	Model Min FAF for CO ₂ < 1% (cfm)	Model Min FAF for CO ₂ < 1% (cfm/person)
1	12.5	NA	NA
54	675	101	1.87
55	687.5	103	1.87
56	700	105	1.88
57	712.5	107	1.88
58	725	108	1.86
59	737.5	110	1.86
60	750	112	1.87

Summary of test method and results

- Propane combustion and supplemental CO₂ were used to simulate human breathing based on RA regulations
- A centrifugal fan simulated a fresh air source, but measurement limitations required an increased number of simulated occupants
- The mandated 12.5 cfm per person for a fresh air source can maintain O₂ and CO₂ levels
- A fresh air flow rate between 1.76–2.12 cfm per person will mitigate CO₂ rise to 1% and still maintain O₂ within 18.5–23% (S.F. 6x – 7x)
- Theoretical model predicts that a minimum fresh air flow rate of 1.87 cfm per person will mitigate CO₂ to 1% (S.F. 6.7x)

Questions?



Cory DeGennaro

CDeGennaro@cdc.gov

DeGennaro, C., Yan, L., Yantek, D., (2021). Fresh Air Flow Required to Maintain Safe Carbon Dioxide Levels and Provide a Breathable Air Environment in a Refuge Alternative. IMECE 2021, ASME. IMECE2021-68680. November 1-5, 2021.

Yan, L., Yantek, D. S., DeGennaro, C. R., Fernando, R. D., (2021). Mathematical Modeling for Carbon Dioxide Level Within Confined Spaces. IMECE 2021, ASME. IMECE2021-68452. November 1-5, 2021.



NIOSH Mining Program
www.cdc.gov/niosh/mining

